

2022-04-07

**REQUEST FOR TENDER  
TZC T 22-2022-03  
PENGUIN POOL FILTRATION ROOM INSTALLATION  
ADDENDUM #1**

---

This addendum shall be incorporated into, and form part of TZC T 22-2022-03 and take precedence over all requirements of the previously issued bid documents including plans. This addendum must be signed by the bidder (signing officer) in the appropriate space and must be attached to the Form for submission by the bidder. This Addendum consists of one (1) page.

**1. Correction to DRAWING A2.01 “PROPOSED NEW LAYOUT”.**

Delete - (3) SPECK PUMPS, MODEL 95-X (7.5HP)

Replace with - (3) SPECK PUMPS, MODEL: WARRIOR 95 (X) AS3 – 3PH.

**2. Part 3 – Scope**

**1.0 SCOPE OF WORK – Additional requirements**

Contractor is to install isolation valving for UV sterilizers during the initial installation and return to install the UV sterilizers (supplied by the Zoo) upon arrival at the Zoo.

Commissioning of the system will be completed in conjunction with Zoo staff or approved parties upon completion of the installation. It is the responsibility of the Contractor to ensure full working operation of the system.

Receipt of the Addendum shall be acknowledged as part of your submission.

The Board of Management of the Toronto Zoo reserves the right to reject any or all Tenders or to accept any quotation, should it deem such action to be in its interests.

If you have any queries regarding this matter, please contact Mr. Peter Vasilopoulos, Supervisor, Purchasing & Supply, at 416-392-5916 or by email [pvasilopoulos@torontozoo.ca](mailto:pvasilopoulos@torontozoo.ca).

Yours truly,

Peter Vasilopoulos  
Supervisor, Purchasing & Supply

I/we hereby acknowledge receipt of this addendum and make allowance in my bid.

Signed (Must be Signing Officer of Firm)

Name of Firm

Date:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
END OF ADDEDNUM 1