



361A Old Finch Ave.
Toronto, ON M1B 5K7
www.torontozoo.com

Tel: 416-392-5900
Fax: 416-392-5934

2021-02-08

**REQUEST FOR QUOTATION
CARIBOU CAFÉ – WASHROOM UPGRADES
TZC T 02-2021-01
ADDENDUM #1**

This addendum shall be incorporated into, and form part of TZC T 02-2021-01 and take precedence over all requirements of the previously issued bid documents including plans. This addendum must be signed by the bidder (signing officer) in the appropriate space and must be attached to the Form for submission by the bidder. This Addendum consists of three (3) pages.

1. DELETE DRAWINGS:

SHEET NUMBER	SHEET NAME	ISSUE DATE
A002	SCHEDULES	2021-01-25
M102	MECHANICAL DETAILS, LEGEND AND DRAWING LIST	2021-01-25
M203	AFRICAN PAVILION PLUMBING AND HVAC MODIFICATION	2021-01-25
E-2.0	ELECTRICAL PLAN BUILDING	2021-01-25
E-7.1	ELECTRICAL SINGLE LINE DIAGRAM	2021-01-25

REPLACE WITH DRAWINGS:

SHEET NUMBER	SHEET NAME	ISSUE DATE
A002	SCHEDULES	2021-02-02
M102	MECHANICAL DETAILS, LEGEND AND DRAWING LIST	2021-02-04
M203	AFRICAN PAVILION PLUMBING AND HVAC MODIFICATION	2021-02-04
E-2.0	ELECTRICAL PLAN BUILDING	2021-02-03
E-7.1	ELECTRICAL SINGLE LINE DIAGRAM	2021-02-03

1. Question:

Faux Tree Branch Door Handle (Drawing A002 Door Hardware Specification) : Could you provide detailed Specification and approved Vendors info, so we can ask for quote accordingly?

Answer:

Please refer to drawing A003, note 2 at bottom left of drawing for a description.

2. Question:

Are there any sub trades for this job requires affiliated union labour ?

Answer:

No. Fair Wage Policy is applicable.

3. Question:

Please let us know if the following trades working on Toronto Zoo projects must be union affiliated:

- 1.1.Masonry
- 1.2.Metal fabrication.
- 1.3.Glazing.
- 1.4.Carpentry.
- 1.5.Drywall.
- 1.6.Painting.
- 1.7.Sprinklers.
- 1.8.Mechanical.
- 1.9.Electrical.

Answer:

No. Fair Wage Policy is applicable.

4. Question:

Please let us know if supplementary bid form part 5 can be e-mailed 24 hours after tender closing.

Answer:

Yes where noted, forms can be submitted 24 hours after stipulated closing date by email..

5. Question:

Please let us know if we can e-mail before tender closing the tender documents and deliver the original documents with courier after tender closing. If it will be not permitted, please provide to the bidders Covid procedures for the tender delivery and Covid procedures for tender envelop opening.

Answer:

1. Submission – Temporary process - In view of the current situation with COVID 19 and to limit personal interaction, on an temporary basis submissions for this Request for Proposal can be submitted electronically by email in a PDF file, prior to the submission deadline to the following email address

purchasing@torontozoo.ca

and note the following:

- a. Subject of the file to be: RFP# - Title of RFP – Vendor name.
- b. Amendments to a Proposal may be submitted via the same methods, at any time prior to the Closing Time.
- c. It is the Supplier's sole responsibility to ensure its Bid is received by the Submission Deadline in accordance with the requirements of this RFP. The receipt of Bids can be delayed due to a number of factors including "internet traffic", file transfer size and transmission speed. The Supplier should allow sufficient time to

download, complete and upload, as applicable, the submission forms comprising its Bid and any attachments.

A Bid will only be considered to be submitted once it has been received by the Toronto Zoo. The time of such receipt is reflected by the time received stamped by the Toronto Zoo's email application

6. Question:

For the above said tender, last time at the time of closing we had a word from siemens that the existing MCC is absolute and they don't have a solution. The bucket mounting can't be provided. Is it possible to get a clarity on this from the consultant? Please refer to the drawing E-7.1.

Answer:

Please reference revised electrical drawings in this addendum.

7. Question:

Drawing A002 has specifications for doors and frames, however all doors are existing. Can you please let us know why the specifications for existing doors are included on the drawing?

Answer:

All doors are to remain but repaired and refinished and all hardware shall be replaced.

8. Question:

Please confirm if contractor will pay for painting inspection cost noted in items 3.8.1.2. of Section 09 91 12.

Answer:

No painting inspections from a third party are required.

9. Question:

Thank you for the arranging of the review of the existing door handle. We can not find in hardware catalogs the existing handle. Can you please provide manufacturer name and catalog number for the handle? If you do not have this information, can you please provide shop drawings from previous project? If you do not have the shop drawings, can you please confirm that the existing handle will be templated on site and new handles will be custom manufactured

Answer:

Please refer to drawing A003, note 2 at bottom left of drawing for a description. Handles will be templated with the Consultant providing a CAD file for the GC to refer to.

Receipt of the Addendum shall be acknowledged as part of your submission.

The Board of Management of the Toronto Zoo reserves the right to reject any or all Tenders or to accept any quotation, should it deem such action to be in its interests.

If you have any queries regarding this matter, please contact Mr. Peter Vasilopoulos, Supervisor, Purchasing & Supply, at 416-392-5916 or by email pvasilopoulos@torontozoo.ca.

Yours truly,

Peter Vasilopoulos
Supervisor, Purchasing & Supply

I/we hereby acknowledge receipt of this addendum and make allowance in my bid.

Signed (Must be Signing Officer of Firm)

Name of Firm

Date: