

2022-02-15

**REQUEST FOR TENDERS
REPLACEMENT OF TRANSFORMERS
VAULTS #1, #2, #28 & #29
RFQ 08 (2022-01)
ADDENDUM #1**

This addendum shall be incorporated into, and form part of RFQ 08 (2022-01) and take precedence over all requirements of the previously issued bid documents including plans. This addendum must be signed by the bidder (signing officer) in the appropriate space and must be attached to the Form for submission by the bidder. This Addendum consists of one (1) page and the attached documents.

1. Delete SCOPE OF WORK - 3.1.10 and replace with the following

3.1.10 Extend and terminate the existing transformer secondary cables to the new pad mount transformer as required. All cables are copper, unless otherwise stated. Wire sizes to be confirmed by contractor. All existing transformers are single phase units.

- 3.1.10.1 Vault #1 contains a set of #2 awg.
- 3.1.10.2 Vault #2 contains a set of 500 kcmil & #4/0 awg.
- 3.1.10.3 Vault #28 contains a set of #6 awg, #2 awg & #2 awg (AL).
- 3.1.10.4 Vault #29 contains a set of 4/0 awg.

Receipt of the Addendum shall be acknowledged as part of your submission.

The Board of Management of the Toronto Zoo reserves the right to reject any or all Tenders or to accept any quotation, should it deem such action to be in its interests.

If you have any queries regarding this matter, please contact Mr. Peter Vasilopoulos, Supervisor, Purchasing & Supply, at 416-392-5916 or by email pvasilopoulos@torontozoo.ca.

Yours truly,

Peter Vasilopoulos
Supervisor, Purchasing & Supply

I/we hereby acknowledge receipt of this addendum and make allowance in my bid.

Signed (Must be Signing Officer of Firm)

Name of Firm _____

Date: _____

END OF ADDENDUM 1