

2022-07-19

**REQUEST FOR QUOTATION  
LIBRARY REFURBISHMENT  
RFQ 34 (2022-06)  
ADDENDUM #4**

---

This addendum shall be incorporated into, and form part of RFQ 34 (2022-06) and take precedence over all requirements of the previously issued bid documents including plans. This addendum must be signed by the bidder (signing officer) in the appropriate space and must be attached to the Form for submission by the bidder. This Addendum consists of one (1) page and the attached documents.

**1. QUESTION:**

Since the doors on site are already painted would it not make sense to provided paint grade solid core wood doors and paint to match the existing?

**RESPONSE:**

Yes. For all new doors, use solid core wood. The existing door that will be relocated as the new entrance to the “Event Staff” room, will need to be painted to match the new doors, in both sides. Toronto Zoo will provide the paint for all five (5) doors.

Receipt of the Addendum shall be acknowledged as part of your submission.

The Board of Management of the Toronto Zoo reserves the right to reject any or all Tenders or to accept any quotation, should it deem such action to be in its interests.

If you have any queries regarding this matter, please contact Mr. Peter Vasilopoulos, Supervisor, Purchasing & Supply, at 416-392-5916 or by email pvasilopoulos@torontozoo.ca.

Yours truly,

Peter Vasilopoulos  
Supervisor, Purchasing & Supply

I/we hereby acknowledge receipt of this addendum and make allowance in my bid.

Signed (Must be Signing Officer of Firm)

Name of Firm

Date:

---

---

---